SPECIAL MEETING OF THE VILLAGE OF MARCELLUS HELD ON SEPTEMBER 23, 2013 AT THE VILLAGE HALL

PRESENT: John P. Curtin, Mayor See List

Patrick W. Cox, Trustee Sally Tallman, Trustee Jeff Brown, Attorney

ABSENT: None

Mayor Curtin opened the informational meeting at 7:18pm and introduced MRB Engineers Jim Oberst, who conducted the meeting and answer questions related to the project.

Sewer Consolidation Project

An Informational Meeting on Sewer Reconstruction Project was held after the last regular Board meeting on September $23^{\rm rd}$, conducted by MRB Engineers Jim Oberst and Dave Willard. Our Sewer Consolidation Project is moving ahead rather well. Following implementation of the sump pump redirection program to reduce flow into the plant, and the televising and cleaning of sewer lines in the Village, Town and School District, those areas in need of repair were identified. The work has also included a major surveying project to accurately map the infrastructure, including manholes, and an on-going attempt to secure necessary easements to complete the project.

Two parts of the project were completed this summer, including the relining of Scotch Hill sanitary sewer lines, which pipes also transmit sewage from part of Town Sewer District #2. This \$100,000 project included a Community Development Block Grant of \$50,000 to the Village. An emergency repair of the sanitary sewer line on Meadow Street, costing \$30,000, also took place, the relining of which lines will wait until budgetary constraints have been addressed.

Early in August 2013, the Board awarded a bid of over \$163,000 for cured-in-place lining of almost 4,000 LF of sanitary sewer pipe in the Village, Town and School District. This work will begin at the end of September and should take about two weeks to complete, without any interruption to residents.

At a Special Meeting to be held on October 9, 2013, the Board will meet to open bids for another part of the sewer reconstruction project, which consists of furnishing labor, materials, equipment and bypass pumping for the replacement of 8-inch diameter sanitary sewer with approximately 1,000 feet of new 12-inch and 300 feet of 15-inch diameter sewer. Work will be conducted within the NYSDOT road right of way on North Street, as well as on back lot easements off of North Street. Work also includes spot repairs on portions of 8-inch diameter sewer along with the replacement of a duplex grinder pump station off Orange Street. It is hoped that this major part of the project will be concluded by the end of the year, although final restoration might have to wait until the spring of 2014.

Mayor Curtin asked for a motion to adjourn the meeting, Trustee Cox made a motion to adjourn the meeting, seconded by Trustee Tallman. All members voted aye and the hearing was closed.

Meeting was adjourned at 7:41 p.m.

 Dawn M. O'Hara Village Clerk	